

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1190007

Product: Fixed Ceiling Luminaire

Type: CANOPUS
variants: 22000/840, 26000/840, 30000/840

Rating: 230 V, 50/60 Hz, max.201 W LED, IP65, ta = 35°C, Proction Class I

Ordering firm: TREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech Republic

Manufacturer: TREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech Republic

Factories: TREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 803268-01/01 of: 14.12.2018, 803268-01/02 of: 16.11.2018

A sample of the product was found to be in conformity with:

ČSN EN 60598-1 ed. 6:15, ČSN EN 60598-2-1:97, ČSN EN 62471:09 Blue light hazard only, ČSN EN 55015 ed. 4:14,
ČSN EN 61547: ed. 2:10, ČSN EN 61000-3-2 ed. 4:15, ČSN EN 61000-3-3 ed. 3 :14

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 803268 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU), 117/2016 Sb. (2014/30/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.01.2022

07.01.2019

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



803268-01