



Ref. Certif. No.

CZ-3140

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Industrial LED luminaire

Name and address of the applicant

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the manufacturer

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the factory

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

220-240 V, 50/60 Hz, max.118 W, IP66,
ta 40, 45, 50, 55 or 60 °C, Class I luminaire

Trademark / Brand (if any)

TREVOS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PRIMA LED Ex a.bft PCc cccc/ddd e f

Additional information (if necessary may also be reported on page 2)

X Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2020,
IEC 60598-2-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

230160-01/01 of: 22.09.2023

This CB Test Certificate is issued by the National Certification Body

Elektrotechnický zkušební ústav, s. p.
Pod lisem 129/2, 182 00 Praha 8, Troja
Czech Republic

Date: 25.09.2023

Miroslav Sedláček
Certification and Inspection Manager

* C E R / C Z - 3 1 4 0 *

230160-01

PRIMA LED Ex a.bft PCc cccc/ddd e f

a = number of LED modules rows (1 or 2)

b = length of 2, 4 or 5 feet (ft)

cccc = lumen flux from 1600 to 20000 lm

ddd = CRI and CCT - 830, 840, 850 and 865

e = "DALI" = version with digital dimmable driver DALI

or

" " = light fitting without digital dimmable driver DALI

f = "1F" = light fitting with 1-phase 3 core through-wiring

or

"3F" = light fitting with 3-phase 5 core through-wiring

or

" " = light fitting without through-wiring

Additional information (if necessary)

Elektrotechnický zkušební ústav, s. p.
Pod lisem 129/2, 182 00 Praha 8, Troja
Czech Republic

Date: 25.09.2023



Signature:



Miroslav Sedláček
Certification and Inspection Manager